

CERTIFICATE

Certificate holder

FISCHER
Mess- und Regeltechnik GmbH
Bielefelder Str. 37a
32107 Bad Salzuflen

Product

Draught diverter

Type, Model

DS21...

Testing basis

DIN 4754-2:2015-03
Certification scheme Draught diverter and Level controller (2016-01)

Mark of conformity



Registration No.

10S001

Valid until


2020-10-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2016-02-11


Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body



ANNEX

Page 1 of 1

Certificate

10S001 dated 2016-02-11

Technical Data

Model: differential pressure gauge
Nominal pressure: 25 bar
Rated voltage: 250 V AC, 5 A or 30 V DC, 0,4 A
Switching hysteresis: 2,5 % accumulated value of measuring range
Ambient temperature: -10 °C to +70 °C
Medium temperature: -10 °C to +85 °C

**Testing laboratory/
Inspection body**

TÜV NORD CERT GmbH
Am TÜV 1
30519 Hannover

Test report(s)

SSW 1710/15 dated 2015-10-07

