

CERTIFICATE

Certificate holder

FISCHER
Mess- und Regeltechnik GmbH
Bielefelder Str. 37a
32107 Bad Salzuflen

Product

Filling controls

Type, Model

NK10...

Testing basis

DIN 4754-3:2015-03
Certification scheme Draught diverter and Level controller (2016-01)

Mark of conformity



Registration No.

10F001

Valid until


2020-10-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2016-02-11


Dipl.-Wi.-Ing. (FH) Sören Scholz
Head of Certification Body



ANNEX

Page 1 of 1

11111111

10F001 dated 2016-02-11

Technical Data

Measuring device: float system
Transfer of measured values: values: mechanically by float rod with bellow
Operating pressure: max. 20 bar (depending on the design)
Ambient temperature: -10 °C to +70 °C
Medium temperature: -10 °C to +400 °C (depending on the design)
Rated voltage: 250 V AC, 6 A or 250 V DC, 0,25 A
Installation position: horizontal

Testing laboratory/ Inspection body

TÜV NORD CERT GmbH
Am TÜV 1
30519 Hannover

Test report(s)

FBW 1810/15 dated 2015-10-07

